

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 11:35 am

PWS ID: UTAH02018 **Name:** MANTUA TOWN WATER SYSTEM
Legal Contact: MANTUA **Rating:** Approved
ADRIANA FORSGREN **Rating Date:** 06/24/1996
Address: 409 N MAIN **Activity Status:** Active
MANTUA, UT 84324
Phone Number: 435-723-7054
City Served (Area):
County: BOX ELDER COUNTY
System Type: Community **Last Inv Update:** 04/25/2011 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 10/14/2008 **Total Dsgn Cap:**
Population: 761 **Surveyor:** RICHARD WORLEY **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office Phone Numbers	Emergency	Email Address
AC	FORSGREN, ADRIANA		435-723-7054		

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	225
Combined	Unknown	0	5
Commercial	Unknown	0	6
			236 Total Svc Connections

Storage

Total Storage: 670,000 GAL **Number of Units:** 3 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	150,000 GAL	Concrete		A	
ST002	STORAGE FACILITY ST002	Ground	500,000 GAL	Concrete		A	
ST003	STORAGE FACILITY ST003	Ground	20,000 GAL	Concrete		A	

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	GIRLS CAMP CHLORINATOR		A	
TP002	MANTUA WELL 2 CHLORINATOR		P	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	GIRLS CAMP SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS002	FLUME HOLLOW SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS003	MANTUA WELL NO 1	Active	WL	12	325 GPM	380 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS004	MANTUA WELL NO 2	Active	WL	8	700 GPM	700 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS005	UTAH02004 BRIGHAM CITY	Inactive	CC				No	SW	Emergency		

**Reports measured flow for wells, approved design capacity for all other sources.*